

CF1.0	Engineering Conditions of Acceptability
CF1.1	For use only in or with complete equipment where the acceptability of the combination is determined by Underwriters Laboratories Inc. When installed in an end-product, consideration must be given to the following:
CF1.5	The following secondary output circuits are SELV: All
CF1.6	The following secondary output circuits are at hazardous energy levels: All
CF1.11	The power supply terminals and/or connectors are: Suitable for field wiring
CF1.12	The maximum investigated branch circuit rating is: 30 A
CF1.13	The investigated Pollution Degree is: 2
CF1.14	The front bezel complies with the requirements for a: V-1 flame rating
CF1.19	The following end-product enclosures are required: Fire, Electrical